


### Notes

1. Concrete 2500 PSI
2. Reinforcing Grade 40
3. All work in compliance with 2013 CBC
4. Tank base for use with tanks supplied by Sequoia Gas Arcata & Fortuna UNO.
5. Tank base for single family residential use only.



|  |   |                             |              |
|--|---|-----------------------------|--------------|
| <br><b>CHAPMAN ENGINEERING</b><br>RCE # 040310<br>P.O. Box 1123<br>ARCATA, CA 95521<br>707-826-9412 | Propane Tank Base - 172 gallon propane tank |                             |              |
|  | OWNER: Sequoia Gas Company                  |                             |              |
|  | SCALE: NTS                                  | ADDRESS: Various            |              |
|  | DATE: 12-15-07                              | APPROVED BY: MARVIN CHAPMAN |              |
|  | CADD FILE: TANKBASE                         | DRAWN BY: M. CHAPMAN        | SHEET 1 OF 1 |